

Exhibit B - Corporations Air Handler Units

Name	Manufacturer Name	Model	Area Served	Location	CFM	MCC	RF (HP/FLA)	SF (HP/FLA)	Has VFD?
AHU-01	Pace	87-53787-01	Hall A	West Mezz CS Mech (L-A)	46,000	MCC-4	25 / 38	50 / 72	TRUE
AHU-02	Pace	87-53787-01	Hall B1	West Mezz CS Mech (L-B)	46,000	MCC-4	25 / 38	50 / 72	TRUE
AHU-03	Pace	87-53787-02	Hall B1	West Mezz CS Mech (L-B)	46,000	MCC-4	25 / 38	50 / 72	TRUE
AHU-04	Pace	87-53787-03	Hall C	West Mezz CS Mech (L-C)	46,000	MCC-5	25 / 38	50 / 72	TRUE
AHU-05	Pace	87-53787-03	Hall C	West Mezz CS Mech (L-C)	46,000	MCC-5	25 / 38	50 / 72	TRUE
AHU-06	Pace	87-53787-04	Hall C	West Mezz CS Mech (Rm 5)	46,000	MCC-5	25 / 38	50 / 72	FALSE
AHU-07	Pace	87-53787-05	Hall C	West Mezz BS Mech (Rm 18)	46,000	MCC-6	25 / 38	50 / 72	TRUE
AHU-08	Pace	87-53787-06	Hall C	West Mezz BS Mech (Rm 16)	46,000	MCC-6	25 / 38	50 / 72	TRUE
AHU-09	Pace	87-53787-34	Hall B1	West Mezz BS Mech (Rm 15)	46,000	MCC-7	25 / 38	50 / 72	TRUE
AHU-10	Pace	87-53787-07	Hall B1	West Mezz BS Mech (Rm 12)	46,000	MCC-7	25 / 38	50 / 72	TRUE
AHU-11	Pace	87-53787-34	Hall A	West Mezz BS Mech (349)	46,000	MCC-7	25 / 38	50 / 72	TRUE
AHU-12	Pace	87-53787-08	Hall A	West Upper Mechanical (6A)	34,000	MCC-1	20 / 31	40 / 59	FALSE
AHU-13	Pace	87-53787-09	Hall B2	West Upper Mechanical CS (Rm 5)	46,000	MCC-2	25 / 38	50 / 72	TRUE
AHU-14	Pace	87-53787-10	Hall B2	West Upper Mechanical BS (Rm 11)	46,000	MCC-3	25 / 38	50 / 72	TRUE
AHU-15	Pace	87-53787-11	Lobby A & B	West Mezz CS Mech (L-A)	46,000	MCC-2	20 / 31	40 / 59	TRUE
AHU-16	Pace	87-53787-12	Lobby B & C	West Mezz CS Mech (L-C)	46,000	MCC-2	20 / 31	40 / 59	TRUE
AHU-17	Pace	87-53787-13	Rm 16,17,18 & 19	West Mezz BS Mech (Fac Office))	46,000	MCC-2	40 / 59	100 / 124	TRUE
AHU-18	Pace	87-53787-14	Rm 12,13,14 & 15	West Mezz BS Mech (352)	46,000	MCC-2	40 / 59	100 / 124	FALSE
AHU-19	Pace	87-53787-15	6A Foyer	West Upper Mechanical CS (Rm 4)	46,000	MCC-2	40 / 59	100 / 124	FALSE
AHU-20	Pace	87-53787-16	Atrium GL-UL	West Upper Mechanical BS (Rm 11)	46,000	MCC-3	25 / 38	50 / 72	FALSE
AHU-21	Pace	87-53787-17	Rm 1,2,3 & 6CD	West Upper Mechanical CS (Rm 2)	46,000	MCC-2	40 / 59	100 / 124	FALSE
AHU-22	Pace	87-53787-18	Rm 4,5 & 6AB	West Upper Mechanical CS (Rm 4)	46,000	MCC-2	40 / 59	100 / 124	FALSE
AHU-23	Pace	87-53787-19	Rm 7,8,9 & 6EF	West Upper Mechanical BS (Rm 10)	46,000	MCC-2	40 / 59	100 / 124	TRUE
AHU-24	Pace	87-53787-20	Rm 10,11 & 6AB	West Upper Mechanical BS (Rm 8)	46,000	MCC-2	40 / 59	100 / 124	FALSE
AHU-25	Pace	87-53787-22	West Cityside Corr.	West Upper Mechanical CS (Rm 3)	46,000	MCC-2	25 / 38	50 / 72	FALSE
AHU-26	Pace	87-53787-22	West Haw. Corr	West Upper Mechanical BS (Rm 9)	34,000	MCC-3	15 / 23	40 / 59	FALSE
AHU-27	Pace	87-53787-23	West Kitchen	West Upper Mechanical (6DE)	29,000	MCC-1		30 / 44	FALSE
AHU-28	Pace	87-53787-24	Security Office	Security Base (ceiling)	5,200	MCC-6		5 / 8.8	FALSE
AHU-29	Pace	87-53787-25	P-1 & P-2 Offices	P2 AV Storage	6,500	MCC-11		7.5 / 8.8	FALSE
AHU-30	Pace	87-53787-26	Exce. Offices	Executive Office Mech Room	11,400	MCC-1	7.5 / 8.8	15 / 23	TRUE
AHU-31	Pace	0	Ace Parking Office	P2 AV Storage	2,000	MCC-11	2 / 4.1	2.75 / 6	FALSE
AHU-32	Energy Labs	131198-FCH-L	Hall D	East Roof	77,500	MCC-17	40 / 59	125 / 157	TRUE
AHU-33	Energy Labs	131198-FCH-L	Hall D	East Roof	77,500	MCC-17	40 / 59	125 / 157	FALSE
AHU-34	Energy Labs	C120180-FCH-L	Hall E	East Roof	62,100	MCC-17	30 / 44	100 / 124	TRUE
AHU-35	Energy Labs	C1116180-FCH-L	Hall E	East Roof	56,000	MCC-18	30 / 44	100 / 124	FALSE
AHU-36	Energy Labs	131198-FCH-L	Hall F	East Roof	77,500	MCC-15	40 / 59	125 / 157	TRUE
AHU-37	Energy Labs	131198-FCH-L	Hall F	East Roof	77,500	MCC-16	40 / 59	125 / 157	TRUE
AHU-38	Energy Labs	131198-FCH-L	Hall G	East Roof	77,500	MCC-15	40 / 59	125 / 157	TRUE
AHU-39	Energy Labs	131198-FCH-L	Hall G	East Roof	77,500	MCC-16	40 / 59	125 / 157	TRUE
AHU-40	Energy Labs	C103167-FCH-L	Hall H	East Roof	51,000	MCC-13	30 / 44	75 / 96	TRUE
AHU-41	Energy Labs	C103167-FCH-L	Hall H	East Roof	51,000	MCC-14	30 / 44	75 / 96	TRUE
AHU-42	Energy Labs	C103182-FCH-L	Hall H	East Roof	56,000	MCC-13	40 / 59	100 / 124	TRUE
AHU-43	Energy Labs	C91112-FCH-L	Hall H	Lobby H Mechanical	26,500	DPHM 28	15 / 23	40 / 59	TRUE
AHU-44	Energy Labs	C140138-FCH-L	Lobby D	East Roof - 20A	55,100	MCC-18	40 / 59	100 / 124	TRUE
AHU-45	Energy Labs	C6686-FCH-L	Administration	East Upper 20A Mech	15,600	MCC-18	15 / 23	30 / 44	TRUE
AHU-46	Energy Labs	C7999-FCH-L	Lobby D	East Mezz Mech Show E	20,300	MCC-18	15 / 23	40 / 59	TRUE
AHU-47	Energy Labs	C9199-FCH-L	Lobby E Prefunc	East Mezz Mechanical Show E	23,450	DPHM-25	20 / 31	40 / 59	TRUE
AHU-48	Energy Labs	C7986-FCH-L	Lobby E Prefunc	East Mezz Mechanical Show F	17,700	DPHM-26	15 / 23	30 / 44	TRUE
AHU-49	Energy Labs	C7999-FCH-L	Lobby F Prefunc	East Mezz Mechanical Show F	19,500	DPHM-26	20 / 31	40 / 59	TRUE
AHU-50	Energy Labs	C7988-FCH-L	Lobby F Prefunc	East Mezz Mechanical Show G	17,710	DPHM-27	15 / 23	40 / 59	TRUE
AHU-51	Energy Labs	C8099-FCH-L	LobbyG	East Mezz Mechanical Show G	21,400	DPHM-27	20 / 31	40 / 59	TRUE
AHU-52	Energy Labs	C9299-FCH-L	LobbyH	East Mezz Mechanical Show G	24,400	DPHM-27	20 / 31	40 / 59	TRUE
AHU-53	Energy Labs	C6779-FCH-L	LobbyH	Lobby H Mechanical	13,500	DPHM-28	7.5 / 12	20 / 31	FALSE
AHU-54	Energy Labs	C9199-FCH-L	Mezz Stroage	Facilities Lineup Area		MCC-19		25 / 38	FALSE
AHU-55	Energy Labs	C9299-FCH-L	Rm 20 Prefunc.	East Roof - 20A	55,300	MCC-18	40 / 59	100 / 124	TRUE
AHU-56	Energy Labs	C104184-FCH-L	Mtg Rms 21-24	East Roof	53,500	MCC-18	40 / 59	100 / 124	FALSE
AHU-57	Energy Labs	C8399-FCH-L	Mtg Rms 21-24	East Roof	22,000	MCC-16	15 / 23	40 / 59	TRUE
AHU-58	Energy Labs	C7986-FCH-L	Mtg Rms 25-27	East Roof	16,000	MCC-14	15 / 23	30 / 44	TRUE
AHU-59	Energy Labs	C135174-FCH-L	Mtg Rms 25-27	East Roof	68,500	MCC-14	40 / 59	100 / 124	FALSE
AHU-60	Energy Labs	C7999-FCH-L	Mtg Rms 29-30	East Roof	21,000	MCC-13	15 / 23	40 / 59	TRUE
AHU-61	Energy Labs	C103148-FCH-L	Mtg Rms 29-30	East Roof	45,000	MCC-13	30 / 38	75 / 96	TRUE
AHU-62	Energy Labs	C103148-FCH-L	Mtg Rms 31-33	East Roof	45,000	MCC-15	30 / 38	75 / 96	TRUE
AHU-63	Energy Labs	C79112-FCH-L	Mtg Rms 31-33	East Roof	22,000	MCC-17	15 / 23	40 / 59	FALSE
AHU-64	Energy Labs	C92101-FCH-L	Rm 20 Prefunc	East Roof - 20D	25,500	MCC-19	15 / 23	40 / 59	TRUE
AHU-65	Energy Labs	C91101-FCH-L	Rm 20 Prefunc	Facilities Lineup Area	25,500	MCC-19	20 / 31	40 / 59	TRUE
AHU-66	Energy Labs	C91138-FCH-L	Ballroom 20CD	East Roof - 20D	35,000	MCC-19	25 / 38	60 / 77	TRUE
AHU-67	Energy Labs	C110161-FCH-L	Service Corr.	East Roof	52,000	MCC-17	30 / 38	75 / 96	FALSE
AHU-68	Energy Labs	C91138-FCH-L	Ballroom 20AB	East Roof	35,000	MCC-18	25 / 38	60 / 77	FALSE
AHU-69	Energy Labs	C91124-FCH-L	Rm 28ABCDE	East Roof	30,000	MCC-17	15 / 23	50 / 72	TRUE
AHU-70	Energy Labs	C91112-FCH-L	New Kitchen	East Roof	28,500	MCC-17	7.5 / 8.8	40 / 59	FALSE
AHU-71	Energy Labs	C5668-FCH-L	East Kitchen	East Roof	9,000	MCC-17		15 / 23	FALSE
AHU-72	McQuay International	RAH077CLY	Sails Pavilion NE	West Roof Cityside	30,000	MCCU-1	15 / 23	40 / 59	FALSE
AHU-73	McQuay International	RAH077CLY	Sails Pavilion NW	West Upper Roof Cityside	35,000	MCCU-1	15 / 23	50 / 72	FALSE

Name	Manufacturer Name	Model	Area Served	Location	CFM	MCC	RF (HP/FLA)	SF (HP/FLA)	Has VFD?
AHU-74	McQuay International	RAH077CLY	Sails Pavilion SE	West Upper Roof Bayside	35,000	MCCU-2	15 / 23	40 / 59	FALSE
AHU-75	McQuay International	RAH077CLY	Sails Pavilion SW	West Roof Bayside	30,000	MCCU-2	15 / 23	40 / 59	FALSE